

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7167-1522:100 Page 1 of 1

**CATEGORY:** Control Unit (Household)

**LISTEE:** Apex, Div. of Pittway Corp., 165 Eileen Way, Syosset NY 11791  
Contact: David Kalmus (516) 921-6704

**DESIGN:** Models DESTINY-6100, COMP6100 (ENTERGY), DESTINY-6100AN\* and DESTINY-4100\* combination household fire and burglary alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations. Minimum system components:

Destiny-6100, COMP6100	Control Unit
Destiny-4100*, Destiny-6100AN*	Control Unit
BRIDGE	RF Receiver Bridge
RK36, RKLCD, RK36ADT* or RKLCDADT*	Keypad

**RATING:** Primary 120 VAC, 16.5 VAC Secondary, 12 VDC Standby

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as household combination fire and burglary alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:**

1. **Fire Alarm Verification Feature** (delay of fire alarm) is NOT approved for use in California.
2. Burglary and other non-fire functions were not examined.

\*Rev. 10-04-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 3, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager